



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx INE 13.0078X Issue No.:0 Certificate history:
Status: Current
Date of Issue: 2014-06-12 Page 1 of 3

Applicant: NUOVA ASP
Via De Gasperi, 26
I - 20090 Pantigliate (MI)
Italy

Electrical Apparatus: Enclosures EJB
Optional accessory:

Type of Protection: d, d[ia], d[ib], tb, tb[ia] or tb[ib]

Marking: Ex d IIB+H2 T6 or T5 or T4 or T3 Gb
Ex d[ia] IIA or IIB or IIC Ga] IIB+H2 T6 or T5 or T4 or T3 Gb
Ex d[ib] IIA or IIB or IIC] IIB+H2 T6 or T5 or T4 or T3 Gb
Ex tb IIC T85°C or T100°C or T135°C or T200°C Db
Ex tb[ia Da] IIC T85°C or T100°C or T135°C or T200°C Db
Ex tb[ib] IIC T85°C or T100°C or T135°C or T200°C Db


Approved for issue on behalf of the IECEx
Certification Body:

Thierry HOUEIX

Position:

Ex Certification Officer

Signature:
(for printed version)



Date:

2014-06-12



1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

INERIS
Institut National de l'Environnement Industriel
et des Risques
BP n2
Parc Technologique ALATA
F-60550 Verneuil-En-Halatte
France

INERIS

INERIS is accredited by COFRAC under number 5-0045 for certification of products and services
(scope of accreditation is available on website www.cofrac.fr)



IECEx Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Date of Issue: 2014-06-12

Issue No.: 0

Page 2 of 3

Manufacturer: **NUOVA ASP**
Via De Gasperi, 26
I - 20090 Pantigliate (MI)
Italy

Additional Manufacturing
location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition: 6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2007-04 Edition: 6	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-11 : 2011 Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-31 : 2008 Edition: 1	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:
[FR/INE/ExTR.13.0078/00](#)

Quality Assessment Report:

[IT/CES/QAR06.0001/00](#)



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Date of Issue: 2014-06-12

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The metallic enclosures made in aluminum alloy, stainless steel, carbon steel or cast iron are covered by the certificate IECEx INE 13.0079U.

These enclosures can have a blind cover or provided with a glass window. The enclosures can be fitted with tubes 3" in order to assembly two flameproof enclosures separated by a certified sealing filling in accordance with the drawing specified in the descriptive documents.

The cover is fixed by stainless steel screws A4-70 for the enclosures EJB91 and EJB93 and A2-70 for the other enclosures.

Enclosures could be fitted with accessories covered by IECEx component certificates. The list of the components is defined in the technical documentation. The components covered by the certificate IECEx INE 13.0072U could be mounted on the enclosure without their marking plates.

They can contain electrical 'NIS' devices and also 'IS' element covered by separated certificates.

Three different types of batteries defined in the technical documentation could be installed inside the enclosure. These enclosures get the degrees of protection IP66 according to the IEC 60529 standard.

CONDITIONS OF CERTIFICATION: YES as shown below:

The width of the flameproof joints is superior to those specified in tables of IEC 60079-1 standard.

During the installation, the user will take into consideration that pilot light type EFL*PC* underwent only a shock corresponding to an energy of a low risk at 2J.

During the installation, the user will take into consideration that the windows of the enclosures underwent only a shock corresponding to an energy of a low risk at 2J.



IECEx Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 0

Page 1 of 6

Annexe: IECEx INE 13.0078X-00_Annex.pdf

PARAMETERS RELATING TO THE SAFETY

For enclosure without intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:
-60°C or -40°C or -20°C to +40°C or +60°C

Maximum supply voltage : 6.6 kVac or 750 Vdc
Maximum current : 2 000 A
Rated frequency : 0/50/60 Hz

Maximum dissipated powers are defined in the Table 1 for enclosures without window and Table 2 for enclosures with window(s).

For enclosure with intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:
-60°C or -40°C or -20°C to +40°C or +60°C

The minimum ambient temperature must be in accordance with the IS components installed inside the enclosures (Barriers, terminals...)

Maximum supply voltage for Non 'IS' elements : 1000 Vac or Vdc
Maximum supply voltage for "IS" elements : 250 V

Maximum dissipated powers are defined in the Table 1 or 2 for enclosures with thermal probes.
Maximum dissipated powers are defined in the Table 3 for enclosures without thermal probes.

The maximum threshold of thermal probe shall be:

Ambient temperature of the enclosure	Ambient temperature of the IS element	Threshold of release of the thermal probe
40°C	≤ 60°C	55°C ± 5°C
	≤ 70°C	65°C ± 5°C
60°C	≤ 80°C	75°C ± 5°C



IECEX Certificate of Conformity

Certificate No.: IECEX INE 13.0078X

Issue No.: 0

Page 2 of 6

Annexe: IECEX INE 13.0078X-00_Annex.pdf

MARKING

Marking has to be readable and indelible; it has to include the following indications:

A – Enclosures without Intrinsic safety element:

NUOVA ASP
I – 20090 Pantigliate (MI)
EJB...(*)
IECEX INE 13.0078X
(Serial number)
Ex d IIB+H₂ T(**) Gb
Ex Ib IIIC T(**) Db IP66
...°C < Tamb < ...°C (***)
T.Cable : (****)

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

- (*) Type is completed by numbers and/or letters corresponding to size of the enclosure
- (**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
- (***) See parameters relating to the safety.
- (****) See Table 1 or 2

B - Enclosures with Intrinsic safety element [Ia]:

NUOVA ASP
I – 20090 Pantigliate (MI)
EJB...(*)
IECEX INE 13.0078X
(Serial number)
Ex d [Ia IIA or IIB or IIC Ga] IIB+H₂ T(**) Gb
Ex Ib [Ia Da] IIIC T(**) Db IP66
...°C < Tamb < ...°C (***)
T.Cable : (****)

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

- (*) Type is completed by numbers and/or letters corresponding to size of the enclosure
- (**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
- (***) See parameters relating to the safety.
- (****) See Table 1, 2 or 3



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 0

Page 3 of 6

Annexe: IECEx INE 13.0078X-00_Annex.pdf

C - Enclosures with intrinsic safety element [Ib]:

NUOVA ASP

I - 20090 Pantigliate (MI)

EJB...(*)

IECEX INE 13.0078X

(Serial number)

Ex d [Ib IIA or IIB or IIC] IIB+H₂ T(**) Gb

Ex tb [Ib] IIIC T(**) Db IP66

...°C < Tamb < ...°C (***)

T.Cable : (****)

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

(*) Type Is completed by number and/or letters corresponding to size of the enclosure

(**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power

(***) See parameters relating to the safety.

(****) See Table 1, 2 or 3

ROUTINE EXAMINATIONS AND TESTS

None



IECEx Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 0

Page 4 of 6

Annexe: IECEx INE 13.0078X-00_Annex.pdf

TABLE 1: Maximum dissipated power for EJB without windows and/or with IS barrier protected by thermal probes (W)								
Temperature class:	T6/T85°C		T5/T100°C		T4/T135°C		T3/T200°C	
Ambient temperature:	+40°C	+60°C	+40°C	+60°C	+40°C	+80°C	+40°C	+60°C
EJB11	40	18	57	34	96	73	168	145
EJB12	36	16	51	31	86	66	151	131
EJB14	58	26	82	49	138	105	241	209
EJB123	58	26	83	50	139	106	243	211
EJB00	90	40	128	77	214	164	376	326
EJB21UL	98	47	138	84	229	177	399	348
EJB22	103	49	145	88	241	187	420	366
EJB23	126	60	177	108	293	227	512	446
EJB21	133	63	186	114	310	240	540	471
EJB41	152	73	214	131	356	276	621	541
EJB30	168	80	236	144	392	304	684	596
EJB31	143	62	201	124	345	263	608	527
EJB31UL	144	62	202	125	346	265	611	529
EJB51UL	212	92	299	184	511	390	901	781
EJB51	220	95	310	191	530	405	935	810
EJB63UL	284	123	399	245	683	522	1204	1043
EJB63	296	128	416	256	712	544	1256	1088
EJB61UL	407	203	553	355	913	704	1575	1372
EJB61	431	216	586	376	967	746	1668	1453
EJB73	458	229	622	399	1027	792	1772	1543
EJB71	549	275	747	479	1232	951	2127	1852
EJB93	624	312	848	544	1400	1080	2416	2104
EJB91	904	440	1240	784	2040	1576	3544	3080
Allowed operators from IECEx INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets		Operators with LSR or MVQ gaskets	
Allowed accessories from IECEx TUN 12.0025U and IECEx TUN 11.0038U	All except Valve ⁽¹⁾		All excepted Valve ⁽¹⁾		All excepted Valve ⁽¹⁾		-	
Allowed accessories from IECEx EXA 13.0001U ⁽²⁾	All Except Valve ⁽¹⁾		All Except Valve ⁽¹⁾		All Except Valve ⁽¹⁾		-	
TCABLE :	80°C		90°C		115°C		175°C	

⁽¹⁾ The valves are only allowed for dust application.

⁽²⁾ These components can be only used in a minimum ambient temperature until -55°C



IECEX Certificate of Conformity

Certificate No.:

IECEX INE 13.0078X

Issue No.: 0

Page 5 of 6

Annexe: IECEX INE 13.0078X-00_Annex.pdf

TABLE 2:								
Maximum dissipated power for EJB with windows and/or with IS barrier protected by thermal probes (W)								
Temperature class :	T6/T85°C		T5/T100°C		T4/T135°C		T3/T200°C	
Ambient temperature:	+40°C	+60°C	+40°C	+60°C	+40°C	+60°C	+40°C	+60°C
EJB11	40	18	57	34	64	47	64	47
EJB12	36	16	51	31	58	43	58	43
EJB14	58	26	82	49	92	68	92	68
EJB123	58	26	83	50	93	69	93	69
EJB08	90	40	128	77	144	106	144	106
EJB21UL	98	47	138	84	140	103	140	103
EJB22	103	49	145	88	147	108	147	108
EJB23	126	60	177	108	180	132	180	132
EJB21	133	63	186	114	189	139	189	139
EJB41	152	73	214	131	218	160	218	160
EJB30	168	80	236	144	240	176	240	176
EJB31	143	62	201	124	232	170	232	170
EJB31UL	144	62	202	125	234	171	234	171
EJB51UL	212	92	299	184	344	253	344	253
EJB51	220	95	310	191	357	262	357	262
EJB63UL	204	123	399	245	460	338	460	338
EJB63	296	128	416	256	480	352	480	352
EJB61UL	407	203	553	355	626	464	626	464
EJB61	431	215	586	376	663	492	663	492
EJB73	458	229	622	399	704	522	704	522
EJB71	549	275	747	479	845	627	845	627
EJB93	624	312	848	544	980	712	960	712
EJB91	904	440	1240	784	1384	1040	1384	1040
Allowed operators from IECEx INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets		Operators with EPDM, LSR or MVQ gaskets	
Allowed accessories from IECEx TUN 12.0025U and IECEx TUN 11.0038U	All except Valve ⁽¹⁾		All excepted Valve ⁽¹⁾		All excepted Valve ⁽¹⁾		All excepted Valve ⁽¹⁾	
Allowed accessories from IECEx EXA 13.0001U ⁽²⁾	All Except Valve ⁽¹⁾		All Except Valve ⁽¹⁾		All Except Valve ⁽¹⁾		All Except Valve ⁽¹⁾	
TCABLE	80°C		90°C		115°C		115°C	

(1) The valves are only allowed for dust application.

(2) These components can be only used in a minimum ambient temperature until -55°C



IECEx Certificate of Conformity

Certificate No.:

IECEx INE 13.0078X

Issue No.: 0

Page 6 of 6

Annexe: IECEx INE 13.0078X-00_Annex.pdf

TABLE 3:
Maximum dissipated power for EJB with IS barrier without thermal probes protection

Type of enclosure	Ambient temperature of the IS barrier	T6 for ambient : (W)		Type of enclosure	Ambient temperature of the IS barrier	T6 for ambient : (W)	
		40°C	60°C			40°C	60°C
EJB11	60°C	4	NA	EJB31UL	60°C	18	NA
	70°C	8	NA		70°C	39	NA
	80°C	13	4		80°C	61	18
EJB12	60°C	3	NA	EJB51UL	60°C	26	NA
	70°C	8	NA		70°C	57	NA
	80°C	12	3		80°C	90	26
EJB14	60°C	5	NA	EJB51	60°C	27	NA
	70°C	12	NA		70°C	60	NA
	80°C	19	5		80°C	94	27
EJB123	60°C	5	NA	EJB63UL	60°C	35	NA
	70°C	12	NA		70°C	77	NA
	80°C	19	5		80°C	121	35
EJB08	60°C	8	NA	EJB63	60°C	36	NA
	70°C	19	NA		70°C	80	NA
	80°C	30	8		80°C	126	36
EJB21UL	60°C	9	NA	EJB61UL	60°C	89	NA
	70°C	20	NA		70°C	142	NA
	80°C	30	9		80°C	198	89
EJB22	60°C	10	NA	EJB61	60°C	94	NA
	70°C	21	NA		70°C	151	NA
	80°C	31	10		80°C	210	94
EJB23	60°C	12	NA	EJB73	60°C	100	NA
	70°C	25	NA		70°C	160	NA
	80°C	38	12		80°C	223	100
EJB21	60°C	13	NA	EJB71	60°C	120	NA
	70°C	27	NA		70°C	192	NA
	80°C	40	13		80°C	268	120
EJB41	60°C	15	NA	EJB93	60°C	136	NA
	70°C	31	NA		70°C	218	NA
	80°C	46	15		80°C	304	136
EJB30	60°C	16	NA	EJB91	60°C	176	NA
	70°C	34	NA		70°C	283	NA
	80°C	51	16		80°C	398	176
EJB31	60°C	17	NA				
	70°C	39	NA				
	80°C	61	17				



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEX INE 13.0078X	Issue No: 1	Certificate history: Issue No. 1 (2015-01-15) Issue No. 0 (2014-06-12)
Status:	Current	Page 1 of 4	
Date of Issue:	2016-01-15		
Applicant:	NUOVA ASP Via De Gasperi, 26 I - 20090 Pantigliate (MI) Italy		
Electrical Apparatus: Optional accessory:	Enclosures type EJB		
Type of Protection:	d, d[ia], d[ib], Ib, Ib[ia] or Ib[ib]		
Marking:	Ex d IIB+H2 T6 or T5 or T4 or T3 Gb Ex d[ia] IIA or IIB or IIC Ga] IIB+H2 T6 or T5 or T4 or T3 Gb Ex d[ib] IIA or IIB or IIC] IIB+H2 T6 or T5 or T4 or T3 Gb Ex Ib IIC T85°C or T100°C or T135°C or T200°C Db Ex Ib[ia] Da] IIC T85°C or T100°C or T135°C or T200°C Db Ex Ib[ib] IIC T85°C or T100°C or T135°C or T200°C Db		

Approved for issue on behalf of the IECEx
Certification Body:

Thierry HOUËIX

Position:

Ex Certification Officer

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate Issued by:

INERIS
Institut National de l'Environnement Industriel
et des Risques
BP n2
Parc Technologique ALATA
F-93660 Voreuil-En-Halatte
France



IECEX Certificate of Conformity

Certificate No: IECEX INE 13.0078X
Date of Issue: 2015-01-16
Manufacturer: NUOVA ASP
Via De Gasperi, 28
I - 20090 Pantigliate (MI)
Italy

Issue No: 1

Page 2 of 4

Additional Manufacturing
location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60070-0 : 2011 Edition:3.0	Explosive atmospheres - Part 0: General requirements
IEC 60070-1 : 2007-04 Edition:6	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60070-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60070-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "I"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

FR/INE/EXTR13.0078/00

FR/INE/EXTR13.0078/01

Quality Assessment Report:

IT/CES/QAR06.0001/08



IECEX Certificate of Conformity

Certificate No: IECEx INE 13.0078X

Issue No: 1

Date of Issue: 2016-01-15

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The metallic enclosures made in aluminum alloy, stainless steel, carbon steel or cast iron are covered by the certificate IECEx INE 13.0079U.
These enclosures can have a blind cover or provided with a glass window. The enclosures can be fitted with tubes 3" in order to assembly two flameproof enclosures separated by a certified sealing fitting in accordance with the drawing specified in the descriptive documents.
The cover is fixed by stainless steel screws A4-70 for the enclosures EJB91 and EJB93 and A2-70 for the other enclosures. Enclosures could be fitted with accessories covered by IECEx component certificates. The list of the components is defined in the technical documentation. The components covered by the certificate IECEx INF 13.0072U could be mounted on the enclosure without their marking plates.

They can contain electrical 'NIS' devices and also 'IS' element covered by separated certificates.
Three different types of batteries defined in the technical documentation could be installed inside the enclosure.
These enclosures get the degrees of protection IP66 according to the IEC 60529 standard.

CONDITIONS OF CERTIFICATION: YES as shown below:

- The width of the flameproof joints is superior to those specified in tables of IEC 60079-1 standard.
- During the installation, the user will take into consideration that pilot light type EFL*PC* underwent only a shock corresponding to an energy of a low risk at 2J.
- During the installation, the user will take into consideration that the windows of the enclosures underwent only a shock corresponding to an energy of a low risk at 2J.



IECEX Certificate of Conformity

Certificate No: IECEx INE 13.0078X

Issue No: 1

Date of Issue: 2015-01-15

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for Issues 1 and above):

Purpose of the Issue 1 of the certificate IECEx INE 13.0078X:

- Extension of the maximum ambient temperature from +60°C to +80°C
- Application of the new standard IEC 60079-31:2013
- New valve type ECD1** covered by an IECEx certificate.

Annex:

[IECEX INE 13.0078X-01_Annex.pdf](#)



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 1

Page 1 of 6

Annexe: IECEx INE 13.0078X-01_Annex.pdf

PARAMETERS RELATING TO THE SAFETY

For enclosure without intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:
-60°C or -40°C or -20°C to +40°C or +60°C or +80°C

Maximum supply voltage : 6.6 kVac or 750 Vdc
Maximum current : 2 000 A
Rated frequency : 0/50/60 Hz

Maximum dissipated powers are defined in the Table 1 for enclosures without window and Table 2 for enclosures with window(s).

For enclosure with intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:
-60°C or -40°C or -20°C to +40°C or +60°C

The minimum ambient temperature must be in accordance with the IS components installed inside the enclosures (Barriers, terminals...)

Maximum supply voltage for Non 'IS' elements : 1000 Vac or Vdc
Maximum supply voltage for "IS" elements : 250 V

Maximum dissipated powers are defined in the Table 1 or 2 for enclosures with thermal probes.
Maximum dissipated powers are defined in the Table 3 for enclosures without thermal probes.

The maximum threshold of thermal probe shall be:

Ambient temperature of the enclosure	Ambient temperature of the IS element	Threshold of release of the thermal probe
40°C	≤ 60°C	55°C ± 5°C
	≤ 70°C	65°C ± 5°C
80°C	≤ 80°C	75°C ± 5°C



IECEX Certificate of Conformity

Certificate No.: IECEX INE 13.0078X

Issue No.: 1

Page 2 of 6

Annexe: IECEX INE 13.0078X-01_Annex.pdf

MARKING

Marking has to be readable and indelible; it has to include the following indications:

A – Enclosures without Intrinsic safety element:

NUOVA ASP
I – 20090 Pantigliate (MI)
EJB...(*)
IECEX INE 13.0078X
(Serial number)
Ex d IIB+H₂ T(**) Gb
Ex tb IIIC T(**) Db IP66
...°C < Tamb < ...°C (***)
T.Cable : (****)

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

- (*) Type is completed by numbers and/or letters corresponding to size of the enclosure
- (**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
- (***) See parameters relating to the safety.
- (****) See Table 1 or 2

B - Enclosures with intrinsic safety element [ia]:

NUOVA ASP
I – 20090 Pantigliate (MI)
EJB...(*)
IECEX INE 13.0078X
(Serial number)
Ex d [ia IIA or IIB or IIC Ga] IIB+H₂ T(**) Gb
Ex tb [ia Da] IIIC T(**) Db IP66
...°C < Tamb < ...°C (***)
T.Cable : (****)

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

- (*) Type is completed by numbers and/or letters corresponding to size of the enclosure
- (**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
- (***) See parameters relating to the safety.
- (****) See Table 1, 2 or 3



IECEx Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 1

Page 3 of 6

Annexe: IECEx INE 13.0078X-01_Annex.pdf

C - Enclosures with Intrinsic safety element [ib]:

NUOVA ASP

I - 20090 Pantigliate (MI)

EJB...(*)

IECEx INE 13.0078X

(Serial number)

Ex d [Ib IIA or IIB or IIC] IIB+H₂ T(**) Gb

Ex Ib [Ib] IIIC T(**) Db IP66

...°C < Tamb < ...°C (***)

T.Cable : (****)

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

(*) Type is completed by number and/or letters corresponding to size of the enclosure

(**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power

(***) See parameters relating to the safety.

(****) See Table 1, 2 or 3

ROUTINE EXAMINATIONS AND TESTS

None



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 1

Page 4 of 6

Annexe: IECEx INE 13.0078X-01_Annex.pdf

TABLE 1: Maximum dissipated power for EJB without windows and/or with IS barrier protected by thermal probes (W)											
Temperature class :	T6/T85°C		T5/T100°C			T4/T135°C			T3/T200°C		
Ambient temperature:	+40°C	+60°C	+40°C	+60°C	+80°C	+40°C	+60°C	+80°C	+40°C	+60°C	+80°C
EJB11	40	18	57	34	12	96	73	62	168	145	124
EJB12	36	16	51	31	11	86	66	56	151	131	112
EJB14	58	26	82	49	18	138	105	90	241	209	178
EJB123	58	26	83	50	18	139	106	91	243	211	180
EJB08	90	40	128	77	28	214	164	140	376	326	278
EJB21UL	98	47	138	84	33	229	177	149	399	348	294
EJB22	103	49	145	88	34	241	187	157	420	366	310
EJB23	126	60	177	108	42	293	227	191	512	446	377
EJB21	133	63	186	114	44	310	240	202	540	471	398
EJB41	152	73	214	131	51	356	276	232	621	541	457
EJB30	168	80	236	144	56	392	304	256	684	596	504
EJB31	143	62	201	124	43	345	263	225	608	527	445
EJB31UL	144	62	202	125	43	346	265	226	611	529	448
EJB51UL	212	92	299	184	63	511	390	333	901	781	660
EJB51	220	95	310	191	66	530	405	346	935	810	685
EJB63UL	284	123	399	245	84	683	522	445	1204	1043	882
EJB63	296	128	416	256	88	712	544	464	1256	1088	920
EJB61UL	407	203	553	355	146	913	704	610	1575	1372	1163
EJB61	431	215	586	376	155	967	746	646	1668	1453	1232
EJB61R	431	215	586	376	155	967	746	646	1668	1453	1232
EJB73	458	229	622	399	164	1027	792	687	1772	1543	1309
EJB71	549	275	747	479	197	1232	951	824	2127	1852	1570
EJB93	624	312	848	544	224	1400	1080	936	2416	2104	1784
EJB91	904	440	1240	784	320	2040	1576	1360	3544	3080	2620
Allowed operators from IECEx INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			Operators with EPDM, LSR or MVQ gaskets			Operators with LSR or MVQ gaskets		
Allowed accessories from IECEx TUN 12.0025U and 11.0038U and IECEx EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.										
Allowed accessories from IECEx EXA 14.0005U, IECEx EXA 14.0004U, and IECEx EXA 14.0006U.	Can be fitted on all EJB until 80dm3 (Excluding EJB71- EJB91 and EJB 93)										
TCABLE	80°C		90°C			115°C			175°C		

(1) The components covered by the certificate IECEx EXA 13.0001U can be only used in a minimum ambient temperature until -55°C



IECEx Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 1

Page 5 of 6

Annexe: IECEx INE 13.0078X-01_Annex.pdf

TABLE 2: Maximum dissipated power for EJB with windows and/or with IS barrier protected by thermal probes (W)											
Temperature class :	T6/T85°C		T5/T100°C			T4/T135°C			T3/T200°C		
Ambient temperature:	+40°C	+60°C	+40°C	+60°C	+80°C	+40°C	+60°C	+80°C	+40°C	+60°C	+80°C
EJB11	40	18	57	34	12	64	47	30	64	47	30
EJB12	36	16	51	31	11	58	43	27	58	43	27
EJB14	58	26	82	49	18	92	68	44	92	68	44
EJB123	58	26	83	50	18	93	69	44	93	69	44
EJB08	90	40	128	77	28	144	106	68	144	106	68
EJB21UL	98	47	138	84	33	140	103	68	140	103	68
EJB22	103	49	145	88	34	147	108	71	147	108	71
EJB23	126	60	177	108	42	180	132	87	180	132	87
EJB21	133	63	186	114	44	189	139	92	189	139	92
EJB41	152	73	214	131	51	218	160	105	218	160	105
EJB30	168	80	236	144	56	240	176	116	240	176	116
EJB31	143	62	201	124	43	232	170	108	232	170	108
EJB31UL	144	62	202	125	43	234	171	109	234	171	109
EJB51UL	212	92	299	184	63	344	253	161	344	253	161
EJB51	220	95	310	191	66	357	262	167	357	262	167
EJB63UL	284	123	399	245	84	460	338	215	460	338	215
EJB63	296	128	416	256	88	480	352	224	480	352	224
EJB61UL	407	203	553	355	146	626	464	308	626	464	308
EJB61	431	215	586	376	155	663	492	326	663	492	326
EJB61R	431	215	586	376	155	663	492	326	663	492	326
EJB73	458	229	622	399	164	704	522	346	704	522	346
EJB71	549	275	747	479	197	845	627	416	845	627	416
EJB93	624	312	848	544	224	960	712	472	960	712	472
EJB91	904	440	1240	784	320	1384	1040	680	1384	1040	680
Allowed operators from IECEx INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			Operators with EPDM, LSR or MVQ gaskets			Operators with EPDM, LSR or MVQ gaskets		
Allowed accessories from IECEx TUN 12.0025U and 11.0038U and IECEx EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.										
Allowed accessories from IECEx EXA 14.0005U, IECEx EXA 14.0004U, and IECEx EXA 14.0006U.	Can be fitted on all EJB until 80dm ³ (Excluding EJB71- EJB91 and EJB 93)										
TCABLE	80°C		90°C			115°C			115°C		

(1) The components covered by the certificate IECEx EXA 13.0001U can be only used in a minimum ambient temperature until -55°C



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 1

Page 6 of 6

Annexe: IECEx INE 13.0078X-01_Annex.pdf

TABLE 3:
Maximum dissipated power for EJB with IS barrier without thermal probes protection

Type of enclosure	Ambient temperature of the IS barrier	T ₀ /T ₈₅ °C for ambient : (W)		Type of enclosure	Ambient temperature of the IS barrier	T ₀ /T ₈₅ °C for ambient : (W)	
		40°C	60°C			40°C	60°C
EJB11	60°C	4	NA	EJB31UL	60°C	18	NA
	70°C	8	NA		70°C	39	NA
	80°C	13	4		80°C	61	18
EJB12	60°C	3	NA	EJB51UL	60°C	26	NA
	70°C	8	NA		70°C	57	NA
	80°C	12	3		80°C	90	26
EJB14	60°C	5	NA	EJB51	60°C	27	NA
	70°C	12	NA		70°C	60	NA
	80°C	19	5		80°C	94	27
EJB123	60°C	5	NA	EJB63UL	60°C	35	NA
	70°C	12	NA		70°C	77	NA
	80°C	19	5		80°C	121	35
EJB08	60°C	8	NA	EJB63	60°C	36	NA
	70°C	19	NA		70°C	80	NA
	80°C	30	8		80°C	126	36
EJB21UL	60°C	9	NA	EJB61UL	60°C	89	NA
	70°C	20	NA		70°C	142	NA
	80°C	30	9		80°C	198	89
EJB22	60°C	10	NA	EJB61	60°C	94	NA
	70°C	21	NA		70°C	151	NA
	80°C	31	10		80°C	210	94
EJB23	60°C	12	NA	EJB61R	60°C	94	NA
	70°C	25	NA		70°C	151	NA
	80°C	38	12		80°C	210	94
EJB21	60°C	13	NA	EJB73	60°C	100	NA
	70°C	27	NA		70°C	160	NA
	80°C	40	13		80°C	223	100
EJB41	60°C	15	NA	EJB71	60°C	120	NA
	70°C	31	NA		70°C	192	NA
	80°C	46	15		80°C	268	120
EJB30	60°C	16	NA	EJB93	60°C	136	NA
	70°C	34	NA		70°C	218	NA
	80°C	51	16		80°C	304	136
EJB31	60°C	17	NA	EJB91	60°C	176	NA
	70°C	39	NA		70°C	283	NA
	80°C	61	17		80°C	398	176



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx INE 13.0078X	Issue No: 2	<u>Certificate history:</u> Issue No. 2 (2015-05-27) Issue No. 1 (2015-01-15) Issue No. 0 (2014-06-12)
Status:	Current	Page 1 of 4	
Date of Issue:	2015-05-27		
Applicant:	NUOVA ASP Via De Gasperi, 26 I - 20090 Pantigliate (MI) Italy		
Electrical Apparatus: <i>Optional accessory:</i>	Enclosures type EJB		
Type of Protection:	d, d[ia], d[ib], tb, tb[ia] or tb[ib]		
Marking:	Ex d IIB+H2 T6 or T5 or T4 or T3 Gb Ex d[ia] IIA or IIB or IIC Ga] IIB+H2 T6 or T5 or T4 or T3 Gb Ex d[ib] IIA or IIB or IIC] IIB+H2 T6 or T5 or T4 or T3 Gb Ex tb IIC T85°C or T100°C or T135°C or T200°C Db Ex tb[ia] Da] IIC T85°C or T100°C or T135°C or T200°C Db Ex tb[ib] IIC T85°C or T100°C or T135°C or T200°C Db		

Approved for Issue on behalf of the IECEx
Certification Body:

Thierry HOUEIX

Position:

Ex Certification Officer

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

INERIS
Institut National de l'Environnement Industriel
et des Risques
BP n2
Parc Technologique ALATA
F-60550 Verneuil-En-Halatte
France



IECEX Certificate of Conformity

Certificate No: IECEx INE 13.0078X
Date of Issue: 2015-05-27
Manufacturer: NUOVA ASP
Via De Gasperi, 26
I - 20090 Pantigliate (MI)
Italy

Issue No: 2

Page 2 of 4

Additional Manufacturing
location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition:6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2007-04 Edition:6	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[FR/INE/ExTR13.0078/00](#)

[FR/INE/ExTR13.0078/01](#)

[FR/INE/ExTR13.0078/02](#)

Quality Assessment Report:

[IT/CES/QAR06.0001/09](#)



IECEx Certificate of Conformity

Certificate No: IECEx INE 13.0078X

Issue No: 2

Date of Issue: 2015-05-27

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The metallic enclosures made in aluminum alloy, stainless steel, carbon steel or cast iron are covered by the certificate IECEx INE 13.0078U.

These enclosures can have a blind cover or provided with a glass window. The enclosures can be fitted with tubes of maximum diameter 3" and maximum length 200 mm in order to assembly two flameproof enclosures separated by a certified sealing fitting in accordance with the drawing specified in the descriptive documents.

The cover is fixed by stainless steel screws A4-70 for the enclosures EJB91 and EJB93 and A2-70 for the other enclosures. Enclosures could be fitted with accessories covered by IECEx component certificates. The list of the components is defined in the technical documentation. The components covered by the certificate IECEx INE 13.0072U could be mounted on the enclosure without their marking plates.

They can contain electrical 'NIS' devices and also 'IS' element covered by separated certificates.

Three different types of batteries defined in the technical documentation could be installed inside the enclosure.

These enclosures get the degrees of protection IP66 according to the IEC 60529 standard.

CONDITIONS OF CERTIFICATION: YES as shown below:

- The width of the flameproof joints is superior to those specified in tables of IEC 60079-1 standard.
- During the installation, the user will take into consideration that pilot light type EFL*PC* underwent only a shock corresponding to an energy of a low risk at 2J.
- During the installation, the user will take into consideration that the windows of the enclosures underwent only a shock corresponding to an energy of a low risk at 2J.



IECEX Certificate of Conformity

Certificate No: IECEx INE 13.0078X

Issue No: 2

Date of Issue: 2015-05-27

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for Issues 1 and above):

Purpose of the Issue 1 of the certificate IECEx INE 13.0078X:

- Extension of the maximum ambient temperature from +60°C to +80°C
- Application of the new standard IEC 60079-31:2013
- New valve type ECD1** covered by an IECEx certificate.

Purpose of the Issue 2 of the certificate IECEx INE 13.0078X:

- Removal of the restrictions of use of the valves type FCD**** covered by the certificates IECEx EXA 14.0004U, IECEx EXA 14.0005U, IECEx EXA 14.0008U regarding the maximum volume allowed.

Annex:

[IECEX INE 13.0078X-02_Annex.pdf](#)



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 2

Page 1 of 6

Annexe: IECEx INE 13.0078X-02_Annex.pdf

PARAMETERS RELATING TO THE SAFETY

For enclosure without intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:

-60°C or -40°C or -20°C to +40°C or +60°C or +80°C

Maximum supply voltage : 6.6 kVac or 750 Vdc

Maximum current : 2 000 A

Rated frequency : 0/50/60 Hz

Maximum dissipated powers are defined in the Table 1 for enclosures without window and Table 2 for enclosures with window(s).

For enclosure with intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:

-60°C or -40°C or -20°C to +40°C or +60°C

The minimum ambient temperature must be in accordance with the IS components installed inside the enclosures (Barriers, terminals...)

Maximum supply voltage for Non 'IS' elements : 1000 Vac or Vdc

Maximum supply voltage for "IS" elements : 250 V

Maximum dissipated powers are defined in the Table 1 or 2 for enclosures with thermal probes.

Maximum dissipated powers are defined in the Table 3 for enclosures without thermal probes.

The maximum threshold of thermal probe shall be:

Ambient temperature of the enclosure	Ambient temperature of the IS element	Threshold of release of the thermal probe
40°C	≤ 60°C	55°C ± 5°C
	≤ 70°C	65°C ± 5°C
60°C	≤ 80°C	75°C ± 5°C



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 2

Page 2 of 6

Annexe: IECEx INE 13.0078X-02_Annex.pdf

MARKING

Marking has to be readable and indelible; it has to include the following indications:

A – Enclosures without intrinsic safety element:

NUOVA ASP
I – 20090 Pantigliate (MI)
EJB...(*)
IECEX INE 13.0078X
(Serial number)
Ex d IIB+H₂ T(**) Gb
Ex tb IIIC T(**) Db IP66
...°C < Tamb < ...°C (***)
T.Cable : (****)

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

- (*) Type is completed by numbers and/or letters corresponding to size of the enclosure
- (**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
- (***) See parameters relating to the safety.
- (****) See Table 1 or 2

B - Enclosures with intrinsic safety element [ia]:

NUOVA ASP
I – 20090 Pantigliate (MI)
EJB...(*)
IECEX INE 13.0078X
(Serial number)
Ex d [ia IIA or IIB or IIC Ga] IIB+H₂ T(**) Gb
Ex tb [ia Da] IIIC T(**) Db IP66
...°C < Tamb < ...°C (***)
T.Cable : (****)

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

- (*) Type is completed by numbers and/or letters corresponding to size of the enclosure
- (**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
- (***) See parameters relating to the safety.
- (****) See Table 1, 2 or 3



IECEX Certificate of Conformity

Certificate No.: IECEX INE 13.0078X

Issue No.: 2

Page 3 of 6

Annexe: IECEX INE 13.0078X-02_Annex.pdf

C - Enclosures with intrinsic safety element [ib]:

NUOVA ASP

I – 20090 Pantigliate (MI)

EJB...(*)

IECEX INE 13.0078X

(Serial number)

Ex d [ib IIA or IIB or IIC] IIB+H₂ T(**) Gb

Ex Ib [ib] IIIC T(**) Db IP66

...°C < Tamb < ...°C (***)

T.Cable : (****)

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

(*) Type is completed by number and/or letters corresponding to size of the enclosure

(**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power

(***) See parameters relating to the safety.

(****) See Table 1, 2 or 3

ROUTINE EXAMINATIONS AND TESTS

None



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 2

Page 4 of 6

Annexe: IECEx INE 13.0078X-02_Annex.pdf

TABLE 1: Maximum dissipated power for EJB without windows and/or with IS barrier protected by thermal probes (W)

Temperature class :	T6/T85°C		T5/T100°C			T4/T135°C			T3/T200°C		
Ambient temperature:	+40°C	+60°C	+40°C	+60°C	+80°C	+40°C	+60°C	+80°C	+40°C	+60°C	+80°C
EJB11	40	18	57	34	12	96	73	62	168	145	124
EJB12	36	16	51	31	11	86	66	56	151	131	112
EJB14	58	26	82	49	18	138	105	90	241	209	178
EJB123	58	26	83	50	18	139	106	91	243	211	180
EJB08	90	40	128	77	28	214	164	140	376	326	278
EJB21UL	98	47	138	84	33	229	177	149	399	348	294
EJB22	103	49	145	88	34	241	187	157	420	366	310
EJB23	126	60	177	108	42	293	227	191	512	446	377
EJB21	133	63	186	114	44	310	240	202	540	471	398
EJB41	152	73	214	131	51	356	276	232	621	541	457
EJB30	168	80	236	144	56	392	304	256	684	596	504
EJB31	143	62	201	124	43	345	263	225	608	527	445
EJB31UL	144	62	202	125	43	346	265	226	611	529	448
EJB51UL	212	92	299	184	63	511	390	333	901	781	660
EJB51	220	95	310	191	66	530	405	346	935	810	685
EJB63UL	284	123	399	245	84	683	522	445	1204	1043	882
EJB63	296	128	416	256	88	712	544	464	1256	1088	920
EJB61UL	407	203	553	355	146	913	704	610	1575	1372	1163
EJB61	431	215	586	376	155	967	746	646	1668	1453	1232
EJB61R	431	215	586	376	155	967	746	646	1668	1453	1232
EJB73	458	229	622	399	164	1027	792	687	1772	1543	1309
EJB71	549	275	747	479	197	1232	951	824	2127	1852	1570
EJB93	624	312	848	544	224	1400	1080	936	2416	2104	1784
EJB91	904	440	1240	784	320	2040	1576	1360	3544	3080	2620
Allowed operators from IECEx INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			Operators with EPDM, LSR or MVQ gaskets			Operators with LSR or MVQ gaskets		
Allowed accessories from IECEx TUN 12.0025U and 11.0038U and IECEx EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.								-		
Allowed accessories from IECEx EXA 14.0005U, IECEx EXA 14.0004U, and IECEx EXA 14.0006U.	Valves can be fitted on all EJB										
TCABLE	80°C		90°C			115°C			175°C		

(1) The components covered by the certificate IECEx EXA 13.0001U can be only used in a minimum ambient temperature until -55°C



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 2

Page 5 of 6

Annexe: IECEx INE 13.0078X-02_Annex.pdf

TABLE 2: Maximum dissipated power for EJB with windows and/or with IS barrier protected by thermal probes (W)

Temperature class :	T6/T85 °C		T5/T100 °C			T4/T135 °C			T3/T200 °C		
Ambient temperature:	+40 °C	+60 °C	+40 °C	+60 °C	+80 °C	+40 °C	+60 °C	+80 °C	+40 °C	+60 °C	+80 °C
EJB11	40	18	57	34	12	64	47	30	64	47	30
EJB12	36	16	51	31	11	58	43	27	58	43	27
EJB14	58	26	82	49	18	92	68	44	92	68	44
EJB123	58	26	83	50	18	93	69	44	93	69	44
EJB08	90	40	128	77	28	144	106	68	144	106	68
EJB21UL	98	47	138	84	33	140	103	68	140	103	68
EJB22	103	49	145	88	34	147	108	71	147	108	71
EJB23	126	60	177	108	42	180	132	87	180	132	87
EJB21	133	63	186	114	44	189	139	92	189	139	92
EJB41	152	73	214	131	51	218	160	105	218	160	105
EJB30	168	80	236	144	56	240	176	116	240	176	116
EJB31	143	62	201	124	43	232	170	108	232	170	108
EJB31UL	144	62	202	125	43	234	171	109	234	171	109
EJB51UL	212	92	299	184	63	344	253	161	344	253	161
EJB51	220	95	310	191	66	357	262	167	357	262	167
EJB63UL	284	123	399	245	84	460	338	215	460	338	215
EJB63	296	128	416	256	88	480	352	224	480	352	224
EJB61UL	407	203	553	355	146	626	464	308	626	464	308
EJB61	431	215	586	376	155	663	492	326	663	492	326
EJB61R	431	215	586	376	155	663	492	326	663	492	326
EJB73	458	229	622	399	164	704	522	346	704	522	346
EJB71	549	275	747	479	197	845	627	416	845	627	416
EJB93	624	312	848	544	224	960	712	472	960	712	472
EJB91	904	440	1240	784	320	1384	1040	680	1384	1040	680
Allowed operators from IECEx INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			Operators with EPDM, LSR or MVQ gaskets			Operators with EPDM, LSR or MVQ gaskets		
Allowed accessories from IECEx TUN 12.0025U and 11.0038U and IECEx EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.										
Allowed accessories from IECEx EXA 14.0005U, IECEx EXA 14.0004U, and IECEx EXA 14.0006U.	Valves can be fitted on all EJB										
TCABLE	80 °C		90 °C			115 °C			115 °C		

(1) The components covered by the certificate IECEx EXA 13.0001U can be only used in a minimum ambient temperature until -55°C



IECEx Certificate of Conformity

Certificate No.:

IECEx INE 13.0078X

Issue No.: 2

Page 6 of 6

Annexe: IECEx INE 13.0078X-02_Annex.pdf

TABLE 3: Maximum dissipated power for EJB with IS barrier without thermal probes protection							
Type of enclosure	Ambient temperature of the IS barrier	T6/T85°C for ambient : (W)		Type of enclosure	Ambient temperature of the IS barrier	T6/T85°C for ambient : (W)	
		40°C	60°C			40°C	60°C
EJB11	60°C	4	NA	EJB31UL	60°C	18	NA
	70°C	8	NA		70°C	39	NA
	80°C	13	4		80°C	61	18
EJB12	60°C	3	NA	EJB51UL	60°C	26	NA
	70°C	8	NA		70°C	57	NA
	80°C	12	3		80°C	90	26
EJB14	60°C	5	NA	EJB51	60°C	27	NA
	70°C	12	NA		70°C	60	NA
	80°C	19	5		80°C	94	27
EJB123	60°C	5	NA	EJB63UL	60°C	35	NA
	70°C	12	NA		70°C	77	NA
	80°C	19	5		80°C	121	35
EJB08	60°C	8	NA	EJB63	60°C	36	NA
	70°C	19	NA		70°C	80	NA
	80°C	30	8		80°C	126	36
EJB21UL	60°C	9	NA	EJB61UL	60°C	89	NA
	70°C	20	NA		70°C	142	NA
	80°C	30	9		80°C	198	89
EJB22	60°C	10	NA	EJB61	60°C	94	NA
	70°C	21	NA		70°C	151	NA
	80°C	31	10		80°C	210	94
EJB23	60°C	12	NA	EJB61R	60°C	94	NA
	70°C	25	NA		70°C	151	NA
	80°C	38	12		80°C	210	94
EJB21	60°C	13	NA	EJB73	60°C	100	NA
	70°C	27	NA		70°C	160	NA
	80°C	40	13		80°C	223	100
EJB41	60°C	15	NA	EJB71	60°C	120	NA
	70°C	31	NA		70°C	192	NA
	80°C	46	15		80°C	268	120
EJB30	60°C	16	NA	EJB93	60°C	136	NA
	70°C	34	NA		70°C	218	NA
	80°C	51	16		80°C	304	136
EJB31	60°C	17	NA	EJB91	60°C	176	NA
	70°C	39	NA		70°C	283	NA
	80°C	61	17		80°C	398	176



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEX INE 13.0078X	Issue No: 3	Certificate history:
Status:	Current	Page 1 of 4	Issue No. 3 (2017-02-20)
Date of Issue:	2017-02-20		Issue No. 2 (2015-05-27)
Applicant:	NUOVA ASP Via De Gasperi, 26 I - 20090 Pantigliate (MI) Italy		Issue No. 1 (2015-01-15)
Equipment:	Enclosures type EJB		Issue No. 0 (2014-06-12)
Optional accessory:			
Type of Protection:	db, db [ia], db [ib], tb, tb [ia] or tb [ib]		
Marking:	Ex db IIA or IIB or IIB+H2 T6 or T5 or T4 or T3 Gb Ex db [ia] IIA or IIB or IIC Ga] IIA or IIB or IIB+H2 T6 or T5 or T4 or T3 Gb Ex db [ib] IIA or IIB or IIC] IIA or IIB or IIB+H2 T6 or T5 or T4 or T3 Gb Ex tb IIC T85°C or T100°C or T135°C or T200°C Db Ex tb [ia Da] IIC T85°C or T100°C or T135°C or T200°C Db Ex tb [ib] IIC T85°C or T100°C or T135°C or T200°C Db		

Approved for issue on behalf of the IECEx
Certification Body:

Thierry HOUËIX

Position:

Ex Certification Officer

Signature:
(for printed version)

Thierry Houeix

Date:

2017-02-20

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

INERIS
Institut National de l'Environnement Industriel
et des Risques, BP n2
Parc Technologique ALATA
France



IECEX Certificate of Conformity

Certificate No: IECEX INE 13.0078X
Date of Issue: 2017-02-20
Manufacturer: NUOVA ASP
Via De Gasperi, 26
I - 20090 Pantigliate (MI)
Italy

Issue No: 3

Page 2 of 4

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition:6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2014-08 Edition:7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

FR/INE/ExTR13.0078/00
FR/INE/ExTR13.0078/03

FR/INE/ExTR13.0078/01

FR/INE/ExTR13.0078/02

Quality Assessment Report:

IT/CES/QAR06.0001/11



IECEx Certificate of Conformity

Certificate No: IECEx INE 13.0078X

Issue No: 3

Date of Issue: 2017-02-20

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The metallic enclosures made in aluminum alloy, stainless steel, carbon steel or cast iron are covered by the certificate IECEx INE 13.0079U.

These enclosures can have a blind cover or provided with a glass window. The enclosures can be fitted with tubes of maximum diameter 3" and maximum length 200 mm in order to assembly two flameproof enclosures separated by a certified sealing fitting in accordance with the drawing specified in the descriptive documents.

The cover is fixed by stainless steel screws A4-70 for the enclosures EJB91 and EJB93 and A2-70 for the other enclosures.

Enclosures could be fitted with accessories covered by IECEx component certificates. The list of the components is defined in the technical documentation. The components covered by the certificate IECEx INE 13.0072U could be mounted on the enclosure without their marking plates.

They can contain electrical 'NIS' devices and also 'IS' element covered by separated certificates.

Three different types of batteries defined in the technical documentation could be installed inside the enclosure.

As specified in the Annex E of the manufacturer's descriptive documents, a specific configuration of the enclosure type EJB30 can contain:

- A pack batteries using cells type "MP 174565" from SAFT and their associated protective devices
- GPS, GSM/GPRS antennas and relevant receiving apparatus.

These enclosures get the degrees of protection IP66 according to the IEC 60529 standard.

CONDITIONS OF CERTIFICATION: YES as shown below:

- The width of the flameproof joints is superior to those specified in tables of IEC 60079-1 standard.
- During the installation, the user will take into consideration that pilot light type EFL^APC^A underwent only a shock corresponding to an energy of a low risk at 2J.
- During the installation, the user will take into consideration that the windows of the enclosures underwent only a shock corresponding to an energy of a low risk at 2J.



IECEx Certificate of Conformity

Certificate No: IECEx INE 13.0078X

Issue No: 3

Date of Issue: 2017-02-20

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for Issues 1 and above):

Purpose of the Issue 3 of the certificate IECEx INE 13.0078X:

- Application of the standard IEC 60079-1: 2014
- Introduction of a specific variation of enclosure EJB30 including a pack batteries using cells type "MP 174565" from SAFT, the protective devices associated and antennas GPS, GSM/GPRS.
- Increase the maximum supply voltage.

Purpose of the Issue 2 of the certificate IECEx INE 13.0078X:

- Removal of the restrictions of use of the valves type ECD**** covered by the certificates IECEx EXA 14.0004U, IECEx EXA 14.0005U, IECEx EXA 14.0006U regarding the maximum volume allowed.

Purpose of the Issue 1 of the certificate IECEx INE 13.0078X:

- Extension of the maximum ambient temperature from +60°C to +80°C
- Application of the new standard IEC 60079-31:2013
- New valve type ECD1** covered by an IECEx certificate.

Annex:

[IECEx INE 13.0078X-03_Annex.pdf](#)



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 3

Page 1 of 7

Annex: IECEx INE 13.0078X-03_Annex.pdf

PARAMETERS RELATING TO THE SAFETY

For enclosure without intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:
-60°C or -40°C or -20°C to +40°C or +60°C or +80°C

Maximum supply voltage : 13 kVac or 750 Vdc
Maximum current : 2 000 A
Rated frequency : 0/50/60 Hz

Maximum dissipated powers are defined in the Table 1 for enclosures without window and Table 2 for enclosures with window(s).

For enclosure with intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:
-60°C or -40°C or -20°C to +40°C or +60°C

The minimum ambient temperature must be in accordance with the IS components installed inside the enclosures (Barriers, terminals...)

Maximum supply voltage for Non 'IS' elements : 1000 Vac or Vdc
Maximum supply voltage for "IS" elements : 250 V

Maximum dissipated powers are defined in the Table 1 or 2 for enclosures with thermal probes.
Maximum dissipated powers are defined in the Table 3 for enclosures without thermal probes.

The maximum threshold of thermal probe shall be:

Ambient temperature of the enclosure	Ambient temperature of the IS element	Threshold of release of the thermal probe
40°C	≤ 60°C	55°C ± 5°C
	≤ 70°C	65°C ± 5°C
60°C	≤ 80°C	75°C ± 5°C



IECEX Certificate of Conformity

Certificate No.: IECEX INE 13.0078X

Issue No.: 3

Page 2 of 7

Annex: IECEX INE 13.0078X-03_Annex.pdf

MARKING

Marking has to be readable and indelible; it has to include the following indications:

A – Enclosures without intrinsic safety element:

NUOVA ASP
I - 20090 Pantigliate (MI)
EJB...(*)
IECEX INE 13.0078X
(Serial number)
Ex db IIA or IIB or IIB+H2 T(**) Gb
Ex tb IIIC T(**) Db IP66
... °C < Tamb < ... °C (***)
T.Cable : (****)
Cable entry: see instructions

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

- (*) Type is completed by numbers and/or letters corresponding to size of the enclosure
- (**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
- (***) See parameters relating to the safety.
- (****) See Table 1 or 2

B - Enclosures with intrinsic safety element [ia]:

NUOVA ASP
I - 20090 Pantigliate (MI)
EJB...(*)
IECEX INE 13.0078X
(Serial number)
Ex db [ia IIA or IIB or IIC Ga] IIA or IIB or IIB+H₂ T(**) Gb
Ex tb [ia Da] IIIC T(**) Db IP66
... °C < Tamb < ... °C (***)
T.Cable : (****)
Cable entry: see instructions

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

- (*) Type is completed by numbers and/or letters corresponding to size of the enclosure
- (**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
- (***) See parameters relating to the safety.
- (****) See Table 1, 2 or 3



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 3

Page 3 of 7

Annex: IECEx INE 13.0078X-03_Annex.pdf

C - Enclosures with intrinsic safety element [ib]:

NUOVA ASP
I - 20090 Pantigliate (MI)
EJB...(*)
IECEX INE 13.0078X
(Serial number)
Ex db [ib IIA or IIB or IIC] IIA or IIB or IIB+H₂ T(**) Gb
Ex tb [ib] IIIC T(**) Db IP66
...°C < Tamb < ...°C (***)
T.Cable : (****)
Cable entry: see instructions

WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT

- (*) Type is completed by number and/or letters corresponding to size of the enclosure
- (**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
- (***) See parameters relating to the safety.
- (****) See Table 1, 2 or 3

ROUTINE EXAMINATIONS AND TESTS

None: Covered by the component certificate IECEx INE 13.0079U



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 3

Page 4 of 7

Annex: IECEx INE 13.0078X-03_Annex.pdf

TABLE 1: Maximum dissipated power for EJB without windows and/or with IS barrier protected by thermal probes (W)											
Temperature class :	T6/T85°C		T5/T100°C			T4/T135°C			T3/T200°C		
Ambient temperature:	+40°C	+60°C	+40°C	+60°C	+80°C	+40°C	+60°C	+80°C	+40°C	+80°C	+80°C
EJB11	40	18	57	34	12	96	73	62	168	145	124
EJB12	36	18	51	31	11	86	66	56	151	131	112
EJB14	58	26	82	49	18	138	105	90	241	209	178
EJB123	58	26	83	50	18	139	106	91	243	211	180
EJB08	90	40	128	77	28	214	164	140	376	326	278
EJB21UL	98	47	138	84	33	229	177	149	399	348	294
EJB22	103	49	145	88	34	241	187	157	420	366	310
EJB23	126	60	177	108	42	293	227	191	512	446	377
EJB21	133	63	186	114	44	310	240	202	540	471	398
EJB41	152	73	214	131	51	366	276	232	621	541	457
EJB30	168	80	236	144	56	392	304	256	684	596	504
EJB31	143	62	201	124	43	345	263	225	608	527	445
EJB31UL	144	62	202	125	43	346	265	226	611	529	448
EJB51UL	212	92	299	184	63	511	390	333	901	781	660
EJB51	220	95	310	191	66	530	405	346	935	810	685
EJB63UL	284	123	399	245	84	683	522	445	1204	1043	882
EJB63	296	128	416	256	88	712	544	464	1256	1088	920
EJB61UL	407	203	553	355	146	913	704	610	1575	1372	1163
EJB61	431	215	586	376	155	967	746	646	1668	1453	1232
EJB61R	431	215	586	376	155	967	746	646	1668	1453	1232
EJB73	458	229	622	399	164	1027	792	687	1772	1543	1309
EJB71	549	275	747	479	197	1232	951	824	2127	1852	1570
EJB93	624	312	848	544	224	1400	1080	936	2416	2104	1784
EJB91	904	440	1240	784	320	2040	1576	1360	3544	3080	2620
Allowed operators from IECEx INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			Operators with EPDM, LSR or MVQ gaskets			Operators with LSR or MVQ gaskets		
Allowed accessories from IECEx TUN 12.0025U and 11.0038U and IECEx EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.								-		
Allowed accessories from IECEx EXA 14.0005U, IECEx EXA 14.0004U, and IECEx EXA 14.0006U.	Valves can be fitted on all EJB										
TCABLE	80°C		90°C			115°C			175°C		

(1) The components covered by the certificate IECEx EXA 13.0001U can be only used in a minimum ambient temperature until -55°C.



IECEX Certificate of Conformity

Certificate No.:

IECEX INE 13.0078X

Issue No.: 3

Page 5 of 7

Annex: IECEX INE 13.0078X-03_Annex.pdf

TABLE 2: Maximum dissipated power for EJB with windows and/or with IS barrier protected by thermal probes (W)											
Temperature class:	T6/T85°C		T5/T100°C			T4/T135°C			T3/T200°C		
Ambient temperature:	+40°C	+60°C	+40°C	+60°C	+80°C	+40°C	+60°C	+80°C	+40°C	+60°C	+80°C
EJB11	40	18	57	34	12	64	47	30	64	47	30
EJB12	36	16	51	31	11	58	43	27	58	43	27
EJB14	58	26	82	49	18	92	68	44	92	68	44
EJB123	58	28	83	50	18	93	69	44	93	69	44
EJB08	90	40	128	77	28	144	106	68	144	106	68
EJB21UL	98	47	138	84	33	140	103	68	140	103	68
EJB22	103	49	145	88	34	147	108	71	147	108	71
EJB23	126	60	177	108	42	180	132	87	180	132	87
EJB21	133	63	186	114	44	189	139	92	189	139	92
EJB41	152	73	214	131	51	218	160	105	218	160	105
EJB30	168	80	238	144	56	240	176	116	240	176	116
EJB31	143	62	201	124	43	232	170	108	232	170	108
EJB31UL	144	62	202	125	43	234	171	109	234	171	109
EJB51UL	212	92	299	184	63	344	253	161	344	253	161
EJB51	220	95	310	191	66	357	262	167	357	262	167
EJB63UL	284	123	399	245	84	480	338	215	480	338	215
EJB63	296	128	416	256	88	480	352	224	480	352	224
EJB61UL	407	203	553	355	146	626	464	308	626	464	308
EJB61	431	215	586	376	155	663	492	326	663	492	326
EJB61R	431	215	586	376	155	663	492	326	663	492	326
EJB73	458	229	622	399	164	704	522	346	704	522	346
EJB71	549	275	747	479	197	845	627	416	845	627	416
EJB93	624	312	848	544	224	960	712	472	960	712	472
EJB91	904	440	1240	784	320	1384	1040	680	1384	1040	680
Allowed operators from IECEX INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*		Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			Operators with EPDM, LSR or MVQ gaskets			Operators with EPDM, LSR or MVQ gaskets		
Allowed accessories from IECEX TUN 12.0025U and 11.0038U and IECEX EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.										
Allowed accessories from IECEX EXA 14.0005U, IECEX EXA 14.0004U, and IECEX EXA 14.0006U.	Valves can be fitted on all EJB										
TCABLE	80°C		90°C			115°C			115°C		

(1) The components covered by the certificate IECEX EXA 13.0001U can be only used in a minimum ambient temperature until -55°C.



IECEX Certificate of Conformity

Certificate No.:

IECEX INE 13.0078X

Issue No.: 3

Page 6 of 7

Annex: IECEX INE 13.0078X-03_Annex.pdf

TABLE 3: Maximum dissipated power for EJB with IS barrier without thermal probes protection							
Type of enclosure	Ambient temperature of the IS barrier	T6/T85°C for ambient : (W)		Type of enclosure	Ambient temperature of the IS barrier	T6/T85°C for ambient : (W)	
		40°C	60°C			40°C	60°C
EJB11	60°C	4	NA	EJB31UL	60°C	18	NA
	70°C	8	NA		70°C	39	NA
	80°C	13	4		80°C	61	18
EJB12	60°C	3	NA	EJB51UL	60°C	28	NA
	70°C	8	NA		70°C	57	NA
	80°C	12	3		80°C	90	26
EJB14	60°C	5	NA	EJB51	60°C	27	NA
	70°C	12	NA		70°C	60	NA
	80°C	19	5		80°C	94	27
EJB123	60°C	5	NA	EJB63UL	60°C	35	NA
	70°C	12	NA		70°C	77	NA
	80°C	19	5		80°C	121	35
EJB08	60°C	8	NA	EJB63	60°C	36	NA
	70°C	19	NA		70°C	80	NA
	80°C	30	8		80°C	126	36
EJB21UL	60°C	9	NA	EJB61UL	60°C	89	NA
	70°C	20	NA		70°C	142	NA
	80°C	30	9		80°C	198	89
EJB22	60°C	10	NA	EJB61	60°C	94	NA
	70°C	21	NA		70°C	151	NA
	80°C	31	10		80°C	210	94
EJB23	60°C	12	NA	EJB61R	60°C	94	NA
	70°C	25	NA		70°C	151	NA
	80°C	38	12		80°C	210	94
EJB21	60°C	13	NA	EJB73	60°C	100	NA
	70°C	27	NA		70°C	160	NA
	80°C	40	13		80°C	223	100
EJB41	60°C	15	NA	EJB71	60°C	120	NA
	70°C	31	NA		70°C	192	NA
	80°C	46	15		80°C	268	120
EJB30	60°C	16	NA	EJB93	60°C	136	NA
	70°C	34	NA		70°C	218	NA
	80°C	51	16		80°C	304	136
EJB31	60°C	17	NA	EJB91	60°C	176	NA
	70°C	39	NA		70°C	283	NA
	80°C	61	17		80°C	398	176



IECEX Certificate of Conformity

Certificate No.:

IECEX INE 13.0078X

Issue No.: 3

Page 7 of 7

Annex: IECEX INE 13.0078X-03_Annex.pdf

TABLE 4 : List of the components intended to be installed on the enclosures		
Type of component	Certificate number	Editions of the standard
Enclosures	IECEX INE 13.0079U	IEC 60079-0:2011 IEC 60079-1:2014 IEC 60079-31:2013
Operators	IECEX INE 13.0072U	IEC 60079-0:2011 IEC 60079-1:2014 IEC 60079-31:2013
Accessories	IECEX TUN 12.0025U IECEX TUN 11.0038U IECEX EXA 13.0001U	IEC 60079-0:2011 IEC 60079-1:2007(*) IEC 60079-7:2007 (*) IEC 60079-31:2008 (*)
Accessories	IECEX EXA 14.0005U IECEX EXA 14.0004U IECEX EXA 14.0006U	IEC 60079-0:2011 IEC 60079-1:2007(*) IEC 60079-7:2007 (*) IEC 60079-31:2008 (*)

(*) Not concerned by the major technical changes of the last edition of the standard.



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEX Scheme visit www.iecex.com

Certificate No.: IECEX INE 13.0078X

Issue No: 4

Certificate history:

Status: Current

Issue No. 4 (2018-04-04)

Date of Issue: 2018-04-04

Page 1 of 4

Issue No. 3 (2017-02-20)

Applicant: NUOVA ASP
Via Mario Pagano, 7
I - 20090 Trezzano sul Naviglio (MI)
Italy

Issue No. 2 (2015-05-27)

Issue No. 1 (2015-01-15)

Issue No. 0 (2014-06-12)

Equipment: Enclosures type EJB

Optional accessory:

Type of Protection: db, db [Ia], db [Ib], Ib, tb [Ia] or tb [Ib]

Marking:

Ex db IIA or IIB or IIB+H2 T6 or T5 or T4 or T3 Gb
Ex db [Ia] IIA or IIB or IIC Ga] IIA or IIB or IIB+H2 T6 or T5 or T4 or T3 Gb
Ex db [Ib] IIA or IIB or IIC] IIA or IIB or IIB+H2 T6 or T5 or T4 or T3 Gb
Ex tb IIC T85°C or T100°C or T135°C or T200°C Db
Ex tb [Ia Da] IIC T85°C or T100°C or T135°C or T200°C Db
Ex tb [Ib] IIC T85°C or T100°C or T135°C or T200°C Db

Approved for issue on behalf of the IECEX
Certification Body:

Thierry HOUEIX

Position:

Ex Certification Officer

Signature:
(for printed version)

Thierry Houeix

Date:

2018-04-04

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEX Website](http://www.iecex.com).

Certificate issued by:

INERIS
Institut National de l'Environnement Industriel
et des Risques, BP n2
Parc Technologique ALATA
France



IECEX Certificate of Conformity

Certificate No: IECEX INE 13.0078X

Issue No: 4

Date of Issue: 2018-04-04

Page 2 of 4

Manufacturer: NUOVA ASP
Via Mario Pagano, 7
I - 20090 Trezzano sul Naviglio (MI)
Italy

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition:6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2014-06 Edition:7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[FR/INE/ExTR13.0078/04](#)

Quality Assessment Report:

[IT/CES/QAR06.0001/12](#)



IECEX Certificate of Conformity

Certificate No: IECEx INE 13.0078X

Issue No: 4

Date of Issue: 2018-04-04

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The metallic enclosures made in aluminum alloy, stainless steel, carbon steel or cast iron are covered by the certificate IECEx INE 13.0079U. These enclosures can have a blind cover or provided with a glass window. The enclosures can be fitted with tubes of maximum diameter 3" and maximum length 200 mm in order to assembly two flameproof enclosures separated by a certified sealing fitting in accordance with the drawing specified in the descriptive documents.

The cover is fixed by stainless steel screws A4-70 for the enclosures EJB91 and EJB93 and A2-70 for the other enclosures.

Enclosures could be fitted with accessories covered by IECEx component certificates. The list of the components is defined in the technical documentation. The components covered by the certificate IECEx INE 13.0072U could be mounted on the enclosure without their marking plates.

They can contain electrical 'NIS' devices and also 'IS' element covered by separated certificates.

Three different types of batteries defined in the technical documentation could be installed inside the enclosure.

As specified in the Annex E of the manufacturer's descriptive documents, a specific configuration of the enclosure type EJB30 can contain:

- A pack batteries using cells type "MP 174565" from SAFT and their associated protective devices
- GPS, GSM/GPRS antennas and relevant receiving apparatus.

These enclosures get the degrees of protection IP66 according to the IEC 60529 standard.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The width of the flameproof joints is superior to those specified in tables of IEC 60079-1 standard.
- During the installation, the user will take into consideration that pilot light type EFL*PC* underwent only a shock corresponding to an energy of a low risk at 2J.
- During the installation, the user will take into consideration that the windows of the enclosures underwent only a shock corresponding to an energy of a low risk at 2J.



IECEX Certificate of Conformity

Certificate No: IECEx INE 13.0078X

Issue No: 4

Date of Issue: 2018-04-04

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

For the Issue 0 of the certificate IECEx INE 13.0078X

The enclosures are covered by the component certificate IECEx INE 13.0079U certified. The accessories intended to be fitted on the enclosure are also covered by an IECEx component certificate. We have performed the thermal tests on different sizes of enclosures in order to specify the maximum power that could be dissipated inside the enclosure in accordance with the external ambient temperature, the allowed operating temperature of enclosures with windows, the IS elements inside the enclosure.

We have assessed the "schedule of limitation" of the different components and accessories in order to check and eventually limit the condition of use these components (Volume, operating temperature...)

For the Issue 1 of the certificate IECEx INE 13.0078X

Extension of the maximum ambient temperature from +60°C to +80°C

Application of the new standard IEC 60079-31:2013

New type valve ECD1** covered by an IECEx certificate.

Updated of technical documentations and test report in order to correct some mistakes.

For the Issue 2 of the certificate IECEx INE 13.0078X

Removal of the restrictions of use of the valves type ECD**** covered by the certificates IECEx EXA 14.0004U, IECEx EXA 14.0005U, IECEx EXA 14.0006U regarding the maximum volume allowed.

For the Issue 3 of the certificate IECEx INE 13.0078X

Application of the standard IEC 60079-1: 2014.

Introduction of a specific variation of enclosure EJB30 including a pack batteries using cells type "MP 174565" from SAFT, the protective devices associated and antennas GPS, GSM/GPRS.

Increase the maximum supply voltage.

For the Issue 4 of the certificate IECEx INE 13.0078X

Possibility to use the enclosure in ambient temperature 50°C with or without IS element

Annex:

[IECEX INE 13.0078X-04_Annex.pdf](#)



IECEX Certificate of Conformity

Certificate No.: IECEx INE 13.0078X

Issue No.: 4

Page 1 of 8

Annex: IECEx INE 13.0078X-04_Annex.pdf

PARAMETERS RELATING TO THE SAFETY

For enclosure without intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:
-60°C or -40°C or -20°C to +40°C or +50°C or +60°C or +80°C

Maximum supply voltage : 13 kVac or 750 Vdc
Maximum current : 2 000 A
Rated frequency : 0/50/60 Hz

Maximum dissipated powers are defined in the Table 1 for enclosures without window and Table 2 for enclosures with window(s).

For enclosure with intrinsic safety element:

These versions are intended to be used in range of ambient temperatures from:
-60°C or -40°C or -20°C to +40°C or +50°C or +60°C

The minimum ambient temperature must be in accordance with the IS components installed inside the enclosures (Barriers, terminals...)

Maximum supply voltage for Non 'IS' elements : 1000 Vac or Vdc
Maximum supply voltage for "IS" elements : 250 V

Maximum dissipated powers are defined in the Table 1 or 2 for enclosures with thermal probes.
Maximum dissipated powers are defined in the Table 3 for enclosures without thermal probes.

The maximum threshold of thermal probe shall be:

Ambient temperature of the enclosure	Ambient temperature of the IS element	Threshold of release of the thermal probe
40°C	≤ 60°C	55°C ± 5°C
	≤ 70°C	65°C ± 5°C
50°C	≤ 60°C	55°C ± 5°C
	≤ 70°C	65°C ± 5°C
	≤ 80°C	75°C ± 5°C
60°C	≤ 70°C	65°C ± 5°C
	≤ 80°C	75°C ± 5°C



IECEX Certificate of Conformity

Certificate No.: IECEX INE 13.0078X

Issue No.: 4

Page 2 of 8

Annex: IECEX INE 13.0078X-04_Annex.pdf

TABLE 1 (First part): Maximum dissipated power for EJB without window and/or with IS barrier protected by thermal probes (W)							
Temperature class:	T6/T85°C			T5/T100°C			
	Ambient temperature:	+40°C	+50°C	+60°C	+40°C	+50°C	+60°C
EJB11	40	29	18	57	46	34	12
EJB12	36	26	16	51	41	31	11
EJB14	58	42	26	82	66	49	18
EJB123	58	42	26	83	66	50	18
EJB08	90	65	40	128	102	77	28
EJB21UL	98	70	47	138	110	84	33
EJB22	103	74	49	145	116	88	34
EJB23	126	90	60	177	141	108	42
EJB21	133	95	63	186	149	114	44
EJB41	152	110	73	214	171	131	51
EJB30	168	121	80	238	189	144	56
EJB31	143	101	62	201	161	124	43
EJB31UL	144	101	62	202	162	125	43
EJB51UL	212	149	92	299	239	184	63
EJB51	220	155	95	310	248	191	66
EJB63UL	284	199	123	399	319	245	84
EJB63	296	208	128	416	333	256	88
EJB61UL	407	306	203	553	449	355	146
EJB61	431	324	215	586	476	376	155
EJB61R	431	324	215	586	476	376	155
EJB73	458	344	229	622	505	399	164
EJB71	549	413	275	747	606	479	197
EJB93	624	469	312	848	689	544	224
EJB91	904	652	440	1240	1019	784	320
Allowed operators from IECEX INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			
Allowed accessories from IECEX TUN 12.0025U and 11.0038U and IECEX EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.						
Allowed accessories from IECEX EXA 14.0005U, IECEX EXA 14.0004U, and IECEX EXA 14.0006U.	Can be fitted on all EJB.						
T.CABLE	80°C			90°C			

- (1) The components covered by the certificate EXA 13ATEX0009U can be only used in a minimum ambient temperature until -55°C.
 (*) No allowed for enclosure with "IS" barrier.



IECEX Certificate of Conformity

Certificate No.: IECEX INE 13.0078X

Issue No.: 4

Page 3 of 8

Annex: IECEX INE 13.0078X-04_Annex.pdf

TABLE 1 (Second part): Maximum dissipated power for EJB without windows and/or with IS barrier protected by thermal probes (W)								
Temperature class:	T4/T135°C				T3/T200°C			
Ambient temperature:	+40°C	+50°C	+60°C	+80°C (*)	+40°C	+50°C	+60°C	+80°C (*)
EJB11	96	84	73	62	168	156	145	124
EJB12	86	76	66	56	151	141	131	112
EJB14	138	121	105	90	241	225	209	178
EJB123	139	122	106	91	243	227	211	180
EJB08	214	189	164	140	376	350	326	278
EJB21UL	229	202	177	149	399	439	348	294
EJB22	241	213	187	157	420	392	366	310
EJB23	293	259	227	191	512	478	446	377
EJB21	310	273	240	202	540	504	471	398
EJB41	356	314	276	232	621	579	541	457
EJB30	392	346	304	256	684	638	596	504
EJB31	345	302	263	225	608	564	527	445
EJB31UL	346	304	265	226	611	567	529	448
EJB51UL	511	448	390	333	901	836	781	660
EJB51	530	465	405	346	935	868	810	685
EJB63UL	683	598	522	445	1204	1118	1043	882
EJB63	712	624	544	464	1256	1166	1088	920
EJB61UL	913	815	704	610	1575	1468	1372	1163
EJB61	967	863	746	646	1668	1554	1453	1232
EJB61R	967	863	746	646	1668	1554	1453	1232
EJB73	1027	917	792	687	1772	1651	1543	1309
EJB71	1232	1101	951	824	2127	1982	1852	1570
EJB93	1400	1250	1080	936	2416	2251	2104	1784
EJB91	2040	1802	1576	1360	3544	3296	3080	2620
Allowed operators from IECEX INE 13.0072U	Operators with EPDM, LSR or MVQ gaskets				Operators with LSR or MVQ gaskets			
Allowed accessories from IECEX TUN 12.0025U and 11.0038U and IECEX EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.							
Allowed accessories from IECEX EXA 14.0005U, IECEX EXA 14.0004U, and IECEX EXA 14.0006U.	Can be fitted on all EJB.							
T.CABLE	115°C				175°C			

(1) The components covered by the certificate EXA 13ATEX0009U can be only used in a minimum ambient temperature until -55°C.

(*) No allowed for enclosure with "IS" barrier.-



IECEX Certificate of Conformity

Certificate No.:

IECEX INE 13.0078X

Issue No.: 4

Page 4 of 8

Annex: IECEX INE 13.0078X-04_Annex.pdf

TABLE 2 (First part): Maximum dissipated power for EJB with windows and/or with IS barrier protected by thermal probes (W)							
Temperature class :	T6/T85°C			T5/T100°C			
Ambient temperature:	+40°C	+50°C	+60°C	+40°C	+50°C	+60°C	+80°C (*)
EJB11	40	29	18	57	46	34	12
EJB12	36	26	16	51	41	31	11
EJB14	58	42	26	82	66	49	18
EJB123	58	42	26	83	66	50	18
EJB08	90	65	40	128	102	77	28
EJB21UL	98	70	47	138	110	84	33
EJB22	103	74	49	145	116	88	34
EJB23	126	90	60	177	141	108	42
EJB21	133	95	63	186	149	114	44
EJB41	152	110	73	214	171	131	51
EJB30	168	121	80	236	189	144	56
EJB31	143	101	62	201	161	124	43
EJB31UL	144	101	62	202	162	125	43
EJB51UL	212	149	92	299	239	184	63
EJB51	220	155	95	310	248	191	66
EJB63UL	284	199	123	399	319	245	84
EJB63	296	208	128	416	333	256	88
EJB61UL	407	306	203	553	449	355	146
EJB61	431	324	215	586	476	376	155
EJB61R	431	324	215	586	476	376	155
EJB73	458	344	229	622	505	399	164
EJB71	549	413	275	747	606	479	197
EJB93	624	469	312	848	689	544	224
EJB91	904	652	440	1240	1019	784	320
Allowed operators from IECEX INE 13.0072U	Operators with NBR, EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			Operators with EPDM, LSR or MVQ gaskets and pilots lights EFL*PC*			
Allowed accessories from IECEX TUN 12.0025U and 11.0038U and IECEX EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.						
Allowed accessories from IECEX EXA 14.0005U, IECEX EXA 14.0004U, and IECEX EXA 14.0006U.	Can be fitted on all EJB.						
T.CABLE	80°C			90°C			

(1) The components covered by the certificate EXA 13ATEX0009U can be only used in a minimum ambient temperature until -55°C.

(*) No allowed for enclosure with "IS" barrier.



IECEX Certificate of Conformity

Certificate No.: IECEX INE 13.0078X

Issue No.: 4

Page 5 of 8

Annex: IECEX INE 13.0078X-04_Annex.pdf

TABLE 2 (Second part): Maximum dissipated power for EJB with windows and/or with IS barrier protected by thermal probes (W)								
Temperature class :	T4/T135°C				T3/T200°C			
Ambient temperature:	+40°C	+50°C	+60°C	+80°C (*)	+40°C	+50°C	+60°C	+80°C (*)
EJB11	64	69	47	30	64	69	47	30
EJB12	58	62	43	27	58	62	43	27
EJB14	92	100	88	44	92	100	68	44
EJB123	93	100	69	44	93	100	69	44
EJB08	144	155	106	68	144	155	106	68
EJB21UL	140	152	103	68	140	152	103	68
EJB22	147	160	108	71	147	160	108	71
EJB23	180	194	132	87	180	194	132	87
EJB21	189	205	139	92	189	205	139	92
EJB41	218	236	160	105	218	236	160	105
EJB30	240	260	176	116	240	260	176	116
EJB31	232	250	170	108	232	250	170	108
EJB31UL	234	252	171	109	234	252	171	109
EJB51UL	344	371	253	161	344	371	253	161
EJB51	357	385	262	167	357	385	262	167
EJB63UL	460	496	338	215	460	496	338	215
EJB63	480	517	352	224	480	517	352	224
EJB61UL	626	676	464	308	626	676	464	308
EJB61	663	716	492	326	663	716	492	326
EJB61R	663	716	492	326	663	716	492	326
EJB73	704	761	522	346	704	761	522	246
EJB71	845	913	627	416	845	913	627	416
EJB93	960	1037	712	472	960	1037	712	472
EJB91	1384	1502	1040	680	1384	1502	1040	680
Allowed operators from IECEX INE 13.0072U	Operators with EPDM, LSR or MVQ gaskets				Operators with LSR or MVQ gaskets			
Allowed accessories from IECEX TUN 12.0025U and 11.0038U and IECEX EXA 13.0001U (1)	All, excepted valves who are allowed only for dust application.							
Allowed accessories from IECEX EXA 14.0005U, IECEX EXA 14.0004U, and IECEX EXA 14.0006U.	Can be fitted on all EJB.							
T.CABLE	115°C				175°C			

(1) The components covered by the certificate EXA 13ATEX0009U can be only used in a minimum ambient temperature until -55°C.

(*) No allowed for enclosure with "IS" barrier.



IECEx Certificate of Conformity

Certificate No.:

IECEx INE 13.0078X

Issue No.: 4

Page 6 of 8

Annex: IECEx INE 13.0078X-04_Annex.pdf

TABLE 3: Maximum dissipated power for EJB with IS barrier without thermal probes protection

Type of enclosure	Ambient temperature of the intrinsic safety element	T6/T85°C for ambient (W)			Type of enclosure	Ambient temperature of the intrinsic safety element	T6/T85°C for ambient (W)		
		+40°C	+50°C	+60°C			+40°C	+50°C	+60°C
EJB11	60°C	4	NA	NA	EJB31UL	60°C	18	NA	NA
	70°C	8	4	NA		70°C	39	18	NA
	80°C	13	8	4		80°C	61	39	18
EJB12	60°C	3	NA	NA	EJB51UL	60°C	26	NA	NA
	70°C	8	3	NA		70°C	57	26	NA
	80°C	12	8	3		80°C	90	57	26
EJB14	60°C	5	NA	NA	EJB51	60°C	27	NA	NA
	70°C	12	5	NA		70°C	60	27	NA
	80°C	19	12	5		80°C	94	60	27
EJB123	60°C	5	NA	NA	EJB63UL	60°C	35	NA	NA
	70°C	12	5	NA		70°C	77	35	NA
	80°C	19	12	5		80°C	121	77	35
EJB08	60°C	8	NA	NA	EJB63	60°C	36	NA	NA
	70°C	19	8	NA		70°C	80	36	NA
	80°C	30	19	8		80°C	126	80	36
EJB21UL	60°C	9	NA	NA	EJB61UL	60°C	89	NA	NA
	70°C	20	9	NA		70°C	142	89	NA
	80°C	30	20	9		80°C	198	142	89
EJB22	60°C	10	NA	NA	EJB61	60°C	94	NA	NA
	70°C	21	10	NA		70°C	151	94	NA
	80°C	31	21	10		80°C	210	151	94
EJB23	60°C	12	NA	NA	EJB61R	60°C	94	NA	NA
	70°C	25	12	NA		70°C	151	94	NA
	80°C	38	25	12		80°C	210	151	94
EJB21	60°C	13	NA	NA	EJB73	60°C	100	NA	NA
	70°C	27	13	NA		70°C	160	100	NA
	80°C	40	27	13		80°C	223	160	100
EJB41	60°C	15	NA	NA	EJB71	60°C	120	NA	NA
	70°C	31	15	NA		70°C	192	120	NA
	80°C	46	31	15		80°C	268	192	120
EJB30	60°C	16	NA	NA	EJB93	60°C	136	NA	NA
	70°C	34	16	NA		70°C	218	136	NA
	80°C	51	34	16		80°C	304	218	136
EJB31	60°C	17	NA	NA	EJB91	60°C	176	NA	NA
	70°C	39	17	NA		70°C	283	176	NA
	80°C	61	39	17		80°C	398	283	176



IECEX Certificate of Conformity

Certificate No.: IECEX INE 13.0078X

Issue No.: 4

Page 7 of 8

Annex: IECEX INE 13.0078X-04_Annex.pdf

TABLE 4 :		
List of the components intended to be installed on the enclosures		
Type of component	Certificate number	Editions of the standard
Enclosures	IECEX INE 13.0079U	IEC 60079-0:2011 IEC 60079-1:2014 IEC 60079-31:2013
Operators	IECEX INE 13.0072U	IEC 60079-0:2011 IEC 60079-1:2014 IEC 60079-31:2013
Accessories	IECEX TUN 12.0025U IECEX TUN 11.0038U IECEX EXA 13.0001U	IEC 60079-0:2011 IEC 60079-1:2007(*) IEC 60079-7:2007 (*) IEC 60079-31:2008 (*)
Accessories	IECEX EXA 14.0005U IECEX EXA 14.0004U IECEX EXA 14.0006U	IEC 60079-0:2011 IEC 60079-1:2007(*) IEC 60079-7:2007 (*) IEC 60079-31:2008 (*)

(*) Not concerned by the major technical changes of the last edition of the standard.

MARKING

Marking has to be readable and indelible; it has to include the following indications:

A – Enclosures without intrinsic safety element:

- NUOVA ASP
- I - 20090 Trezzano Sul Naviglio (MI)
- EJB...(*)
- IECEX INE 13.0078X
- (Serial number)
- Ex db IIA or IIB or IIB+H2 T(**) Gb
- Ex tb IIIC T(**) Db IP66
- ... °C < Tamb < ... °C (***)
- T.Cable : (****)
- Cable entry: see instructions
- **WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT**

(*) Type is completed by numbers and/or letters corresponding to size of the enclosure

(**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power

(***) See parameters relating to the safety.

(****) See Table 1 or 2



IECEX Certificate of Conformity

Certificate No.: IECEX INE 13.0078X

Issue No.: 4

Page 8 of 8

Annex: IECEX INE 13.0078X-04_Annex.pdf

B - Enclosures with intrinsic safety element [ia]:

- NUOVA ASP
 - I - 20090 Trezzano Sul Naviglio (MI)
 - EJB...(*)
 - IECEX INE 13.0078X
 - (Serial number)
 - Ex db [ia IIA or IIB or IIC Ga] IIA or IIB or IIB+H2 T(**) Gb
 - Ex tb [ia Da] IIIC T(**) Db IP66
 - ...°C < Tamb < ...°C (***)
 - T.Cable : (****)
 - Cable entry: see instructions
 - **WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT**
- (*) Type is completed by numbers and/or letters corresponding to size of the enclosure
(**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
(***) See parameters relating to the safety.
(****) See Table 1, 2 or 3

C - Enclosures with intrinsic safety element [ib]:

- NUOVA ASP
 - I - 20090 Trezzano Sul Naviglio (MI)
 - EJB...(*)
 - IECEX INE 13.0078X
 - (Serial number)
 - Ex db [ib IIA or IIB or IIC] IIA or IIB or IIB+H2 T(**) Gb
 - Ex tb [ib] IIIC T(**) Db IP66
 - ...°C < Tamb < ...°C (***)
 - T.Cable : (****)
 - Cable entry: see instructions
 - **WARNINGS: DO NOT OPEN IF AN EXPLOSIVE ATMOSPHERE MAY BE PRESENT**
- (*) Type is completed by number and/or letters corresponding to size of the enclosure
(**) Temperature class in accordance with Table 1 or 2 regarding to the maximum dissipated power
(***) See parameters relating to the safety.
(****) See Table 1, 2 or 3

ROUTINE EXAMINATIONS AND TESTS

None : Covered by the Ex Component certificate IECEX INE 13.0079U